NO
THIS DRAWING EMBODIES A DESIGN ORIGINATED BY MACRO TECHNOLOGIES LLC AND ALL ARE EXPRESSLY RESERVED. IT IS SUBMITTED UNDER A CONFIDENTIAL RELATIONSHIP FOR A SPECIFIC PURPOSE, AND THE RECIPIENT AGREES BY ACCEPTING THIS DRAWING NOT TO SUPPLY OR DISCLOSE ANY INFORMATION REGARDING IT TO ANY UNAUTHORIZED PERSON, OR TO INCORPORATE IN OTHER PROJECTS ANY SPECIAL FEATURES PECULIAR TO THIS DESIGN. ALL PATENT RIGHTS HERETO ARE EXPRESSLY RESERVED BY MACRO TECHNOLOGIES LLC.

REVISIONS			
LTR	DESCRIPTION	DATE	APPROVAL



IDENTIFIED POPPET DESIGNED TO LEAK AT BREAKAWAY, PREVENTS OVER PRESSURE DUE TO LIQUID - GAS PHASE CHANGE

PERFORMANCE SPECIFICATIONS:

MEDIA: LNG FUELING SERVICE OR INERT GAS & LIQUIDS @ -320° TO +140° F SERVICE TEMP.
PRESSURE RATING: 300 PSIG FUELING, 550 PSIG MAX STATIC W.P.; BURST: 1500 PSIG
RATED FLOW: 50 GPM (LNG)
WEIGHT: 4.1 LBS AS SHOWN
AUTOMATIC MEDIA FLOW SHUT-OFF AT BREAKAWAY
MATERIALS, WETTED PARTS: BRASS, CRES & UHMW
BREAKAWAY LOAD: LEFT END FIXED AND SIDE LOAD AT FITTING END
OF 225 - 275 LBS APPLIED AT RIGHT ANGLE TO AXIS, AT -0- INTERNAL PRESSURE.
RADIOGRAPHY: N/A
IMPACT TEST: EXEMPT PER 323.2.2 & 323.2.3 IN ACCORDANCE WITH UNF-65
PNEUMATIC TEST: 250 PSIG DRY NITROGEN @ 70 °F

REFERENCE ONLY

GENERAL NOTES:

1. ALL COMPONENTS CLEANED PER CGA G-4.1 AND COMPLETED ASSEMBLY SHALL BE PACKAGED IN A SEALED POLY BAG WITH IDENTIFICATION PER WO REQM'TS
2. UNIT IS NON-FIELD SERVICABLE
3. PERMANENTLY MARK ON 2IN DIAMETER OF IDENTIFIED PART: MACRO PART NUMBER, REVISION, AND ASSEMBLY DATE CODE OPERATING PRESSURE: 300 PSIG/20.7 BAR
4. STAMP FLOW ARROW ON FLATS OF IDENTIFIED HEX, OPPOSITE SIDES. FLOW IS LEFT TO RIGHT.
5. ORDER PART NUMBER: 13740-5
SEE S-14390-5 FOR VERSION WITHOUT SENSOR PLUG

-2	-1	BSC	FSCM NO.	PART NUMBER	PART DESCRIPTION	MATERIAL / FINISH SPECIFICATION	ITEM
QUANTITY REQ'D				PARTS LIST			

DRILLED HOLE TOL.
.013 TO .125 = +.004 -.001
.125 TO .250 = +.005 -.001
.250 TO .500 = +.008 -.001
.500 TO .750 = +.008 -.001
.750 TO 1.00 = +.010 -.001
1.00 TO 1.50 = +.012 -.001

NEXT ASSY PART NO.	QUAN

* UNLESS OTHERWISE SPECIFIED *
ALL DIMENSIONS ARE IN INCHES AND ARE TO BE MET BEFORE PLATING
TOLERANCES ARE:
DECIMALS: .XX = ± .030 .XXX = ± .010
ANGULAR: ± .5°
BREAK SHARP EDGES .005-.010 & REMOVE BURRS
MACHINED FILLETS TO BE .010-.030 RADIUS
CONC. = .005 TIR, SQUARENESS = .005 PER INCH
GENERAL FINISH TO BE 100 RMS PER ASA B46.1

MATERIAL / SPEC: NOTED
HEAT TREAT / SPEC: NONE
FINISH / SPEC: NONE

CONTRACT NO.
CUSTOMER SPEC
CUSTOMER
DESIGN ACTIVITY
CHECKED BY
ENGR
DRAWN BY: JD — DATE: 4-16-13

Macro Technologies LLC
12530 - 135th Ave N.E. * Kirkland, WA * 98034

TITLE
LNG BREAKAWAY, 50 GPM FLOW
STRAIGHT END FITTING, SENSOR PLUG

SIZE	CAGE CODE	DRAWING NO.	REV
C	62529	S-13740-5	

SCALE: NONE — AQL LEVEL: — SHEET 1 OF 1